



Coconut Industry Investment Fund – Legaspi Oil Company Inc.

REQUEST FOR QUOTATION

Date: JULY 10, 2026

RFQ No.: **LEG-PL-SVP26-0019**

PR No.: **PURREQ-LEG-PL01-5777**

Company/Business Name: _____
Address: _____
Business/Mayor's Permit No. : _____
TIN: _____
PhilGEPS Registration Number (required): _____

The Coconut Industry Investment Fund – Legaspi Oil Company, Inc. (LEGOIL), through its Bids and Awards Committee (BAC), intends to procure **PERIODIC MAINTENANCE OF FIRE DETECTION AND ALARM SYSTEM (FDAS)** through **Section 34 Small Value Procurement** of the Implementing Rules and Regulations of Republic Act No. 12009.

Please quote your **best offer** for the item/s described herein, subject to the Terms and Conditions provided on this Request for Quotation (RFQ). Submit your quotation duly signed by you or your duly authorized representative not later than the deadline on **JULY 16, 2026 at 5:00PM**.

The following documents are also required to be submitted along with your quotation on the specified deadline above:

Document	Remarks
Copy of 2026 Mayor's or Business Permit	Latest Business/Mayor's Permit issued by the city or municipality where the principal place of business of the bidder is located.
Copy of PhilGeps Registration	Valid PhilGEPS Registration Number/Organization ID/PhilGEPS Certificate of Registration (Platinum Membership) Valid PhilGEPS Registration Number/Organization ID (Red Membership)
BIR Registration Certificate	(BIR Form 2303)
Annual Income Tax Return stamped received by the BIR	For items with ABC above Php 500,000.00
Notarized Omnibus Sworn Statement (GPPB-Prescribed Form)	For items with ABC above Php 50,000.00

For any clarification, you may contact **Syreen Anne B. Madrinian** at mobile no. **0985-111-8760** or email address at smadrinian@ciif.ph or syreen.madrinian@gmail.com

ANGELITA G. RAPADA
Head, BAC Secretariat

4TH FLOOR PALACIO DEL GOBERNADOR GEN. LUNA ST., INTRAMUROS, MANILA
(02) 8892-7961 TO 65
WWW.CIIF.PH

INSTRUCTIONS:

Note: Failure to follow these instructions will disqualify your entire quotation.

1. Do not alter the contents of this form in any way.
2. The use of this RFQ is highly encouraged to minimize errors or omissions of the required mandatory provisions. In case of any changes, bidders must use or refer to the latest version of the RFQ, except when the latest version of the RFQ only pertains to deadline extension.
 - If another form is used other than the latest RFQ, the quotation shall contain all the mandatory requirements/provisions including manifestation on the agreement with the Terms and Conditions below.
 - In case a prospective supplier/service provider submits a filled-out RFQ with a supporting document (i.e., a price quotation in a different format), both documents shall be considered unless there will be discrepancies. In this case, provisions in the RFQ shall prevail.
3. All mandatory technical specifications (with asterisk) must be complied with. Failure to comply with the mandatory requirements shall render the quotation ineligible/disqualified.
4. Quotations may be submitted through electronic mail to smadrinian@ciif.ph
5. Quotations, including documentary requirements, received after the deadline shall not be accepted. For quotations submitted via electronic mail, the date and time of receipt indicated in the email shall be considered.

TERMS AND CONDITIONS:

1. Bidders shall provide the correct and accurate information required in this form.
2. Any interlineations, erasures, or overwriting shall be valid only if they are signed or initialed by you or any of your duly authorized representative/s.
3. Price quotation/s must be valid for a period of forty-five (45) calendar days from the deadline of submission.
4. Price quotation/s, to be denominated in Philippine peso, shall include all taxes, duties, and/or levies payable.
5. Quotations exceeding the Approved Budget for the Contract shall be rejected.
6. In case of two or more bidders are determined to have submitted the Lowest Calculated Quotation/Lowest Calculated and Responsive Quotation, the LEGOIL shall adopt and employ "draw lots" as the tie-breaking method to finally determine the single winning provider in accordance with GPPB Circular 06-2005.
7. The award of the contract shall be made to the lowest quotation which complies with the technical specifications, requirements, and other terms and conditions stated herein.
8. The item/s shall be delivered according to the accepted offer of the bidder at **Plant Site Brgy. Arimbay Legazpi City**
9. Item/s delivered shall be inspected on the scheduled date and time of the LEGOIL. The delivery of the item/s shall be acknowledged upon the delivery to confirm compliance with the technical specifications.
10. Payment shall be made upon confirmation of delivery and submission of the required supporting documents, i.e., Purchase Order and Billing statement, by the supplier, contractor, or consultant. Our Government Servicing Bank, i.e., the Land Bank of the Philippines, shall credit the amount due to the identified bank account of the supplier, contractor, or consultant not earlier than twenty-four (24) hours, but not later than forty-eight (48) hours, upon receipt of our advice. Please note that the corresponding bank transfer fee, if any, shall be chargeable to the account of the supplier, contractor, or consultant.
11. Liquidated damages equivalent to one-tenth of one percent (0.1%) of the value of the goods not delivered within the prescribed delivery period shall be imposed per day of delay. The LEGOIL may terminate the contract once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract, without prejudice to other courses of action and remedies open to it.
12. Warranty Security may be required depending on the nature of the procurement project.

4TH FLOOR PALACIO DEL GOBERNADOR GEN. LUNA ST., INTRAMUROS, MANILA

(02) 8892-7961 TO 65

WWW.CIIF.PH

After having carefully read and accepted the **Instructions and Terms and Conditions**, I/we submit our quotation/s for the item/s as follows:

Detailed Technical Specifications:

SERVICE FOR THE PERIODIC MAINTENANCE OF FIRE DETECTION AND ALARM SYSTEM (FDAS)				
<u>ITEM</u>	<u>SPECIFICATIONS/SCOPE OF WORKS</u>	<u>STATEMENT OF COMPLIANCE</u> (State Comply or Not Comply)		<u>BIDDER'S ACTUAL OFFER</u>
1.PERIODIC MAINTENANCE OF FIRE DETECTION AND ALARM SYSTEM (FDAS)	<u>REFER TO ANNEX A FOR THE DETAILED SCOPE OF WORKS</u>			
WARRANTY:				
LEADTIME:				
DELIVERY ADDRESS: ARIMBAY LEGAZPI CITY, ALBAY BICOL REGION				

FINANCIAL OFFER:

Terms of Payment: Payment shall be made through Landbank within thirty (30) days after Submission of Billing and End-User's Acceptance of the product. A Bank Transfer fee shall be charged against the creditor's account. Payment Details: Banking Institution: _____ Account Number: _____ Account Name: _____ Branch: _____
--

Please quote your best offer for the item/s below. Please do not leave any blank items. Indicate **"0"** if the item being offered is free.

4TH FLOOR PALACIO DEL GOBERNADOR GEN. LUNA ST., INTRAMUROS, MANILA
 (02) 8892-7961 TO 65
WWW.CIIF.PH

PERIODIC MAINTENANCE OF FIRE DETECTION AND ALARM SYSTEM (FDAS)		
Approved Budget for the Contract: 212,946.43		
Quantity (A)	Offered Price per UOM (B)	TOTAL OFFERED QUOTATION (A x B)
1 LOT		In Words: _____ _____ _____ In Figure: _____

Signature Over Printed Name

Position/Designation

Office Telephone/Fax/Mobile Nos.

Email address/e

4TH FLOOR PALACIO DEL GOBERNADOR GEN. LUNA ST., INTRAMUROS, MANILA
(02) 8892-7961 TO 65
WWW.CIIF.PH



Republic of the Philippines
Office of the President

COCONUT INDUSTRY INVESTMENT FUND OIL MILLS GROUP (CIIF-OMG)
(LEGASPI OIL COMPANY, INC., SAN PABLO MANUFACTURING CORPORATION, SOUTHERN
LUZON COCONUT OIL MILL, INC., CAGAYAN DE ORO OIL COMPANY, INC., GRANEXPORT
MANUFACTURING CORPORATION, ILIGAN COCONUT INDUSTRIES, INC.)
4th floor, Palacio Del Gobernador, Gen. Luna St. Intramuros Manila



Annex " A"

PERIODIC MAINTENANCE OF FIRE DETECTION AND ALARM SYSTEM (FDAS)

Scope of Works

- 1 Visual inspection of system device.
- 2 General check up of all indicating and initiating device including the Fire Alarm Panel and;
 - 2.1 Checking and replacement/rewiring of circuitry for possible worn out parts.
 - 2.2 Checking of power supply for proper output regulation, current and voltage.
 - 2.3 Actual testing and replacement (if necessary) of the back up battery during power failure.
 - 2.4 Checking of proper AC input.
- 3 Tightening of lamination and mounting of all loose terminals and screws
- 4 General cleaning and testing of device
 - 4.1 Smoke detectors
 - 4.2 Alarm Bells and manual pull stations
 - 4.3 Annunciators and visual indicators
 - 4.4 Linear heat cable
- 5 Line to ground testing of system wiring for possible grounded or resistance leak
 - 5.1 Conduct grounding check within the system for control panels down to peripherals and fire alarm connected to the system.
 - 5.2 Checking of wiring connections inside terminal box / panels for open or loose connections. Repair and replacement if necessary.
 - 5.3 Checking of terminal box or pull boxes if protective cover is in plate. Replacement to be done if necessary.
- 6 Submission of report and checklist of testing and inspection in 2 copies.

Prepared by:

Princess Elaine P. Arevalo